WWW.IJRPR.COM

**International Journal of Research Publication and Reviews**

Journal homepage: www.ijrpr.com ISSN 2582-7421

# DESIGN AND ECONOMIC ANALYSIS OF HYDROKINETIC TURBINES On A COMPARATIVE REVIEW

***M. Kalyani[1], Dr. V.Rambabu[2]***

[1]Department of Mechanical Engineering, GMRIT Deemed to be University, GMR Nagar, Rajam, Andhra Pradesh, India

**1. ABSTRACT :**

This paper compares four studies on hydrokinetic turbine design and economic feasibility, represented by five supplied research files, and places their findings in the context of field measurement and experimental validation literature. The studies examine household-scale rotor design, energy-system investment, Bayesian shape optimization, and constrained computational-fluid-dynamics (CFD) optimization. The household analysis reports a modeled power coefficient (Cp) near 0.45 for a three-bladed rotor operating near a tip-speed ratio of five and estimates payback under distinct economic settings. The system-level assessment finds stronger investment potential when generation serves local demand than when electricity is sold only to wholesale markets under its assumed costs. Design-by-Morphing with Bayesian search broadens the geometries explored, while adjoint-based optimization refines duct, blade, and hub variables under practical constraints. A ducted 5 kW design reaches a reported Cp of about 0.50 in its numerical evaluation. These results are specific to different configurations and assumptions; they do not establish a universal performance gain or guarantee project viability. A broader assessment shows why measured resource quality, consistent performance definitions, channel effects, device reliability, environmental compatibility, and local electricity value must be evaluated together. A staged workflow is proposed to connect computational design with site screening, matched experiments, open-channel monitoring, and lifecycle economics. The review does not reproduce the original models or establish a new comparative ranking; its purpose is to identify the evidence needed to move from promising optimized geometries to credible project decisions.

This paper compares four studies on hydrokinetic turbine design and economic feasibility, represented by five supplied research files. The studies examine household-scale rotor design, energy-system investment, Bayesian shape optimization, and constrained computational-fluid-dynamics (CFD) optimization. The household analysis reports a modeled power coefficient (Cp) near 0.45 for a three-bladed rotor operating near a tip-speed ratio of five and estimates payback under distinct economic settings. The system-level assessment finds stronger investment potential when generation serves local demand than when electricity is sold only to wholesale markets under its assumed costs. Design-by-Morphing with Bayesian search broadens the geometries explored, while adjoint-based optimization refines duct, blade, and hub variables under practical constraints. A ducted 5 kW design reaches a reported Cp of about 0.50 in its numerical evaluation. These results are specific to different configurations and assumptions; they do not establish a universal performance gain or guarantee project viability. Site measurements, matched experimental validation, and local lifecycle-cost data are needed to connect optimized geometry with reliable energy and credible returns.

**Keywords:** hydrokinetic turbine; river energy; turbine optimization; CFD; Bayesian optimization; economic assessment

## INTRODUCTION

Hydrokinetic turbines convert the kinetic energy of river, tidal, and estuarine currents into electricity without depending on a large elevation difference. They may serve households, isolated communities, or grid-connected users near suitable waterways. Their performance and practicality depend on local current speed and duration, depth, channel geometry, debris, access, and competing waterway uses. Consequently, a high modeled rotor efficiency does not alone determine whether a project can deliver useful and affordable energy.

The supplied research spans technical design and project economics. One study models a household-scale rotor and evaluates investment returns [1]. A second compares off-grid, grid-connected, and wholesale-sale configurations [2]. Two studies focus on geometry optimization: Design-by-Morphing with Bayesian search [3] and constrained CFD optimization of a 5 kW ducted turbine [4]. The report includes five files but represents four distinct studies; duplicate or alternate versions are treated as one contribution. This paper compares their methods, findings, and evidence limits, then identifies steps needed to connect computational design with deployment decisions.




**Figure 1. Conceptual illustration of a submerged river-current turbine; illustrative and not to scale.**

## METHODOLOGY

A narrative comparison was conducted using the five supplied research files as the primary source set. Duplicate or alternate versions were identified before synthesis, leaving four distinct studies. For each contribution, the review extracted the research objective, application, design variables, analytical or computational method, reported outcomes, and stated limitations. Technical guidance and peer-reviewed studies on open-channel measurement, river-resource assessment, technology development, and prototype testing were consulted to frame the validation and deployment discussion [5]–[8]. These supplementary sources provide context; they are not treated as part of the original four-study comparison. Evidence was organized across three linked questions: how turbine geometry affects modeled performance; how economic value changes with the energy-system configuration; and what validation is required before results can support a site-specific decision.

The reported metrics were not pooled. The studies examine different turbine scales, geometries, inflow conditions, numerical methods, reference definitions, and economic boundaries. The review did not reproduce simulations or financial calculations, conduct a new database search, or independently verify the underlying models. Quantitative findings below are therefore attributed to their original study and interpreted within its assumptions.

The comparison separates three evidence levels. First are outputs calculated by a model, such as a predicted Cp curve or a selected project capacity. Second are measurements made in a controlled channel or at a field site, which test some components of the model under specified conditions. Third are long-duration operational and financial outcomes, which incorporate availability, maintenance, seasonal resource variation, and actual energy use. Evidence at one level is informative but cannot automatically substitute for evidence at the next. This distinction matters when a design study reports a peak performance value while an economic study evaluates annual operation under a separate resource and cost model.

The supplementary literature was selected for direct relevance to measurement practice and prototype validation, not to estimate average technology performance. The review is narrative rather than systematic: it does not claim complete coverage of turbine families, ecological studies, permitting regimes, or market designs. No meta-analysis was attempted because the studies use different definitions, scales, and boundary conditions. The conclusions should be read as a structured interpretation of a small evidence base and a guide to the next measurements required.

## MODELING AND ANALYSIS

### Hydrokinetic performance and the system boundary

An unconfined current carries kinetic power through the area occupied by a rotor. For a uniform approach flow, the reference power available in that stream is commonly written as one half of water density multiplied by swept area and the cube of velocity. The power coefficient expresses the fraction of this reference power converted to rotor mechanical power. Electrical output is lower after drivetrain, generator, power-electronics, and storage losses are included. These quantities answer different questions: Cp characterizes a rotor relative to a defined flow reference, whereas delivered electricity depends on the whole conversion chain and its operation.

The cubic dependence on velocity makes the resource estimate sensitive to how representative the measured current is. A short survey that samples a fast patch, a single season, or only the rotor hub height can overstate the energy available over a year. The flow is also spatially nonuniform: velocity changes with depth and distance from banks and bed, and turbulence produces fluctuations around the mean. A useful site model therefore needs a velocity distribution over the proposed swept area, plus the duration and frequency of operating conditions, rather than a single design velocity [5], [6].

A peak Cp is not an annual-energy metric. Annual production depends on the turbine power curve across current speeds, cut-in and cut-out rules, generator loading, downtime, and limits on operation imposed by waterway use. A device may have a high peak coefficient over a narrow operating range yet produce less electricity over a year than a design with a broader curve and higher availability. Conversely, a modest peak Cp can still be useful where a predictable current coincides with local demand and avoids costly fuel or grid purchases. This distinction links rotor optimization to system optimization without collapsing them into one number.

The reference area and flow definition must also be stated. A ducted turbine can change the velocity distribution through a rotor, but coefficients may be normalized to different areas or velocities. Comparisons become misleading if one study uses electrical power and another mechanical power, or if one

denominator uses local duct velocity and another uses freestream velocity. Any quoted coefficient should be accompanied by its power boundary, reference velocity, reference area, and operating point. The original studies should be interpreted according to their own definitions; a common normalization would require raw data that are not available here.

**From reduced-order analysis to CFD**

Blade-element momentum methods offer a relatively low-cost way to screen rotor configurations and operating points. They combine sectional blade forces with a momentum description of flow through the rotor. Their value is practical: many blade shapes, rotational speeds, and loads can be examined before detailed computation or fabrication. Their limits follow from idealizations in the underlying assumptions. Strongly nonuniform inflow, support structures, free-surface effects, nearby boundaries, complex ducting, and three-dimensional flow may require additional corrections or a higher-fidelity model. BEM is therefore a design aid whose accuracy depends on the hydrofoil data and relevance of its assumptions to the site.

CFD resolves more geometry and flow detail, but its predictions remain model outputs. Mesh density, domain size, boundary conditions, turbulence closure, rotor representation, and convergence criteria affect the result. A steady calculation may be economical for initial screening, while transient calculations may be needed to capture changing blade loads or unsteady wakes. Computational cost grows when geometry and operating conditions are varied, motivating surrogate-assisted searches, adjoint sensitivities, or carefully chosen design experiments. These tools reduce search cost; they do not remove the need for grid checks, uncertainty reporting, or validation against measured quantities.

For the studies reviewed here, the strength of the computational claim depends on the question asked. The household rotor study uses BEM to estimate rotor-level performance and feeds economic assumptions into a payback analysis [1]. The shape-search study asks whether a flexible geometry representation can be explored with a limited CFD budget [3]. The constrained 5 kW study asks whether coupled duct, blade, and hub variables can be refined while satisfying packaging and thickness requirements [4]. These are different contributions to a design process. They cannot be ranked by reported Cp values alone because their objectives, parameter spaces, and validation boundaries differ.

**Rotor performance and household economics**

Puertas-Frías et al. use blade-element momentum (BEM) theory to compare household-scale horizontal-axis rotor designs. Their analysis considers blade configuration, tip-speed ratio, hydrofoil characteristics, and tip and hub losses around a nominal rotor radius of about 1 m. The authors report that a three-bladed rotor designed near a tip-speed ratio of five can attain Cp around 0.45 under the modeled conditions [1]. Their economic evaluation uses discounted payback period and internal rate of return. Estimated discounted payback is approximately 3–6 years in the advanced-economy case and 4–7 years in the developing-economy case; these ranges depend on the study's cost, support, and electricity-value assumptions [1].




**Figure 3. Conceptual river installation of a three-bladed hydrokinetic turbine; generated illustration, not a documented deployment.**

**System-level investment assessment**

Bigatton et al. model three energy-system configurations: an off-grid island serving local demand, a grid-connected industrial user reducing purchased electricity, and a producer selling output to the wholesale market. A linear optimization model selects capacity and operating decisions, including storage where appropriate, using resource, demand, price, and cost inputs [2]. The authors find investment potential when hydrokinetic generation serves local demand, with or without a grid connection, while wholesale-only sales are not profitable under the assumed costs. The result emphasizes that project value depends on the service and market served, rather than turbine output alone [2].

**Geometry optimization and numerical evaluation**

Sheikh et al. combine Design-by-Morphing with mixed-variable, multi-objective Bayesian optimization (MixMOBO) to explore draft-tube and hub shapes while limiting expensive CFD evaluations [3]. Their approach targets two constraints in conventional optimization: a narrow parameterization can exclude useful geometries, while broader searches can require many simulations. The study demonstrates a computational framework for joint shape exploration; it does not by itself establish fabrication readiness or long-term operational reliability [3].

Park et al. couple CFD, adjoint sensitivities, and gradient-based optimization across 37 design variables covering duct, blade, and hub geometry. The model includes a minimum duct-thickness constraint and space for a 5 kW generator. The optimized configuration has a thin cambered duct with a

rounded leading edge, an upstream-projecting hub, and modified blade twist and chord. RANS/URANS evaluations report Cp up to about 0.50, compared with an approximately 0.45 freestream reference turbine in that study [4]. This modeled difference belongs to the specified configurations and conditions; it is not a universal gain applicable across sites or turbine designs.





**Figure 2. Integrated resource-to-economics pathway synthesized from the reviewed studies.**

## RESULTS AND DISCUSSION

Table 1 summarizes the four contributions. Taken together, they show that optimization methods can improve or broaden modeled designs, while economic analyses identify the conditions under which the resulting electricity may have value. The evidence remains fragmented: geometry studies emphasize flow and shape, and economic studies rely on particular cost and resource assumptions.

| Study | Method | Reported result and interpretation |
|---|---|---|
| **Puertas-Frías et al. [1]** | BEM rotor design; discounted payback and return analysis. | Cp around 0.45 for a three-bladed design near TSR 5; payback estimates vary by economic setting. |
| **Bigatton et al. [2]** | Linear optimization of capacity and operation across three system configurations. | Local-demand cases show investment potential; wholesale-only sales are unattractive under the assumed costs. |
| **Sheikh et al. [3]** | Design-by-Morphing with mixed-variable, multi-objective Bayesian search. | Flexible draft-tube and hub exploration with fewer costly evaluations; computational evidence needs engineering validation. |
| **Park et al. [4]** | CFD, adjoint sensitivities, and gradient optimization of 37 variables with practical constraints. | A 5 kW ducted design reaches Cp up to about 0.50 in RANS/URANS evaluation; the comparison is configuration-specific. |

**Table 1. Comparison of the four reviewed studies.**

### Technical performance and evidence

**What the reported coefficients establish**

The household design result is evidence that a three-bladed rotor near the stated operating regime can perform well in the authors' BEM framework [1]. It provides a candidate geometry and operating point for further testing. It does not establish what fraction of an annual river resource will be converted to electricity, how the rotor responds to debris or changing inflow, or whether projected payback will be realized at another site. Similarly, the ducted design's reported Cp near 0.50 is evidence of a promising numerical configuration under the study's setup [4]. Its comparison with a freestream reference is informative within that study, but the difference should not be treated as a guaranteed field gain.

A design improvement can move value between objectives. A duct may change the velocity distribution and increase rotor loading, but it also adds wetted surface, material, structural load, and a larger envelope. A hub or blade adjustment may improve a modeled coefficient while changing torque, thrust, fatigue loading, or susceptibility to debris. The design objective should therefore include system constraints: structural loads, manufacturing tolerances, installation clearance, generator range, service access, and safe shutdown. A geometry that is optimal under a narrow CFD objective can be inferior after these constraints are included.

**Optimization methods and the question of search coverage**

Design-by-Morphing combined with mixed-variable Bayesian optimization is useful when a designer wants to explore a shape family that is difficult to describe with a few conventional parameters [3]. A surrogate model can guide the next expensive CFD evaluation toward promising regions while accounting for categorical or discrete choices. The benefit is broader exploration for a limited evaluation budget. Risks include surrogate error in sparsely sampled regions and a shape grammar that excludes useful geometries or generates shapes that are difficult to manufacture. Reporting the initial design set, search domain, constraints, surrogate uncertainty, and final confirmation simulations is necessary to judge convergence.

Adjoint-based optimization can efficiently provide sensitivities of a performance objective to many continuous design variables, as demonstrated by the 37-variable constrained study [4]. This can make gradient-guided refinement less expensive than perturbing each variable separately. It works best where the design variables and objective are sufficiently smooth and the optimizer can follow a useful local gradient. Results can depend on the starting design and may settle in a local optimum. The method also requires constraints that represent the engineering problem, such as duct thickness and generator fit. Combining broad exploration with local adjoint refinement is plausible, but each final candidate still needs independent high-resolution evaluation and physical testing.

A fair evaluation of optimization includes more than the best objective value. Useful reporting includes the baseline geometry, number and cost of simulations, search bounds, failed or infeasible evaluations, constraint margins, repeatability of the final solution, and performance over off-design conditions. If one approach finds a slightly better peak coefficient after many more simulations, the practical trade-off differs from a method that offers a robust design quickly. Robustness matters because turbulence, roughness, manufacturing tolerances, and model parameters vary in deployment. Final geometries should be tested across Reynolds numbers, water levels, velocities, and loading conditions.

Both rotor studies report favorable modeled performance, but the values cannot be compared as if they came from a matched experiment. The household rotor's Cp near 0.45 and the ducted turbine's Cp up to about 0.50 arise from different geometries, reference setups, and evaluation conditions [1], [4]. The latter study provides a within-study freestream reference, but the results still require experimental confirmation. A fair assessment of design gains would test baseline and optimized geometries under the same inflow, measurement procedure, and reference-area definition.

**Economic feasibility and deployment**

The project boundary determines whether an attractive rotor becomes an attractive investment. Household payback estimates in [1] reflect the costs, support conditions, and electricity values used in that study. The system-level analysis in [2] distinguishes an islanded local-demand case, a grid-connected industrial user that offsets purchases, and wholesale-only sales. That distinction changes the value assigned to each kilowatt-hour. Electricity consumed locally may avoid a retail tariff or diesel generation, while a wholesale market can offer a lower or more variable price and impose transaction requirements. The studies are consistent in showing that use case matters, even though they model different scales and boundaries.

A locally useful system may need storage, dispatchable backup, or a grid connection to meet demand when current speed falls. Storage can improve service continuity but adds capital cost, conversion losses, replacement needs, and control complexity. For an off-grid project, the comparison is between the reliability and cost of the whole supply portfolio and the incumbent alternative. For a grid-connected user, avoided purchases, export compensation, demand charges, interconnection costs, and curtailment rules may affect value. A wholesale project requires forecasts, balancing arrangements, and sufficient scale to absorb fixed development and maintenance costs.

Project economics should report a transparent cash-flow boundary. Capital expenditure can include rotor, duct, support, generator, cabling, control system, transport, installation, civil works, and permitting. Operating costs include inspection, debris removal, corrosion protection, repair, access, insurance, and eventual removal or refurbishment. The analysis should state whether financing, taxes, replacement intervals, salvage value, and residual equipment value are included. Payback period is easy to communicate but suppresses the timing and risk of later cash flows. A discounted metric represents time value yet remains sensitive to discount rate, lifetime, energy output, and local tariff assumptions.

Uncertainty should be presented in terms decision makers can inspect. A base case may use credible resource and cost inputs, while low and high cases test plausible seasonal flow, availability, installation cost, replacement frequency, electricity prices, and discount rates. Scenario analysis can ask whether the project remains feasible when several unfavorable variables occur together. Sensitivity analysis identifies the inputs that most affect value and helps target data collection. If feasibility hinges on a narrow assumption about annual operating hours, measuring a representative seasonal flow record may be more valuable than refining a rotor geometry whose performance is already adequate.

The economic comparison should preserve the distinction between technical potential and realizable output. Resource calculations that assume rated operation whenever velocity exceeds a threshold may omit shutdowns, electrical losses, access delays, and maintenance. A reliable estimate needs a power curve paired with a time series or distribution of site conditions and a defensible availability factor. If a system serves local load, the temporal match between generation and demand matters: equal annual totals do not imply equal reliability. Time-step analysis is appropriate where storage, backup, or export constraints determine the design [2].

A useful way to compare the four studies is to follow the causal chain from geometry to cash flow. The household study links rotor parameters to modeled performance and then to payback under specified economic conditions [1]. The system study begins with resource and demand assumptions and optimizes capacity and operation for different market arrangements [2]. The Bayesian search and adjoint study focus on how geometry can be explored or refined within a CFD framework [3], [4]. Each link is valuable, but the chain remains incomplete because the optimized geometries have not been passed through one shared sequence of manufacturing, matched testing, site operation, and local economic evaluation.

This separation also explains why the studies do not contradict one another when they report different performance or feasibility results. A high rotor coefficient answers a hydrodynamic question at a selected operating point; a favorable investment case answers whether expected output and avoided or sold energy justify the modeled costs. The second result can change while the first stays fixed if the market price, load profile, financing, installation method, or maintenance assumption changes. Conversely, a better rotor coefficient may have little economic effect if the site has a poor resource, the device is unavailable for long periods, or additional structure costs exceed the value of the extra output.

The design objective should be selected after the project use case is defined. A household system may prioritize robust output across variable speeds, simple maintenance, and a low-cost control system. An industrial user may value predictable output that reduces purchased electricity during operating hours. A wholesale project may require a different scale, interconnection, and forecasting strategy. This does not imply that each use case requires an entirely different turbine; it means that the operating point, control strategy, balance-of-system design, and preferred trade-offs should be evaluated against the service the project must provide.

The comparison therefore supports a conditional conclusion: optimization expands or improves the candidate design space, but the value of that improvement depends on the flow regime and the system boundary. Geometry, control, site selection, and economics should be treated as connected decision variables. A multi-stage process can make this connection explicit by passing measurable outputs from one stage to the next: geometry and load estimates to prototype design; measured power curves to annual-energy models; operating logs to availability assumptions; and site-specific cash flows to an investment decision. This is more informative than treating a numerical optimum as the final product.

**A deployment screening sequence**

The first screen is physical access and channel suitability. A candidate reach needs enough depth and width for the chosen rotor and support, a current distribution that can be characterized, and a safe installation and retrieval plan. Bathymetry and cross-sections matter because channel geometry influences both the resource and the effect of a device on the waterway. Sediment movement, bank stability, seasonal water levels, ice or flood conditions, navigation, irrigation scheduling, and existing infrastructure should be reviewed early. A fast but highly split or inaccessible reach may be less feasible than a slower reach with stable flow and clear access [6].

A second screen is compatibility with the waterway's primary function and users. In canals, a device can change water levels, local velocities, and energy grade, potentially affecting deliveries, freeboard, spillways, or downstream hydropower. In rivers, concerns may include navigation, recreation, fishing, flood conveyance, sediment transport, and sensitive habitat. A field plan should be developed with the waterway operator and communities before detailed design. Where a device is removable or seasonal operation is possible, the operating plan should specify who may request shutdown, how quickly retrieval can occur, and who is responsible for inspection [5].

A third screen is electrical integration and service. The system needs a route to local loads or the grid, protection against water ingress, safe grounding and isolation, and controls that respond to overspeed or abnormal conditions. A remote site may need communications, telemetry, and spare parts that tolerate limited access. Overall cost can be dominated by foundations, retrieval equipment, or interconnection rather than the rotor. Concept design should compare device configurations and deployment methods in the same cost model instead of adding balance-of-system costs only after rotor optimization.

The economic studies converge on the importance of context. Household payback estimates vary with local costs and support, while system-level results

favor configurations that displace local electricity purchases or meet local demand [1], [2]. A project assessment should combine measured current profiles and availability with demand or price, installation and maintenance costs, financing, storage, and waterway constraints. Sensitivity analysis is necessary where these inputs are uncertain; results from another region should not be transferred without local data.

## Complementary optimization methods

### Model hierarchy and decision relevance

A useful model hierarchy avoids spending the highest computational effort on questions that can be resolved more cheaply. Analytical estimates and BEM can screen rotor scale, blade count, and operating range. Surrogate models can help explore complex geometry families. CFD can evaluate candidates where three-dimensional flow and duct interaction are central. Experiments can test predictions, while field deployments establish annual availability and service burden. Each step should be retained only if it changes a design or investment decision. This hierarchy also clarifies uncertainty: a precise numerical optimum is not more decision-relevant than an approximate model if resource and cost inputs remain uncertain.

No single optimization method can optimize all project objectives unless those objectives and constraints are explicitly represented. Maximizing Cp may conflict with minimizing thrust, material use, fabrication complexity, or maintenance. A multi-objective design should expose a Pareto set so decision makers can see trade-offs rather than treating one weighted score as universal. Practical constraints should be introduced early, including minimum thickness, generator space, structural load limits, access, and waterway clearance. A robust candidate retains useful performance when inputs vary, not only at a single nominal point.

The optimization studies address different design challenges. Design-by-Morphing and MixMOBO expand the available draft-tube and hub shapes while managing expensive evaluations [3]. Adjoint-based gradient optimization updates many continuous geometry variables while enforcing constraints such as duct thickness and generator packaging [4]. Their approaches are complementary rather than interchangeable: the suitable method depends on the design space, variable types, computational budget, and constraints. Neither numerical search method replaces experimental testing or lifecycle assessment.

### SITE RESOURCE ASSESSMENT AND CHANNEL EFFECTS

Annual resource estimation begins with joint measurement of flow and channel geometry. A site survey should map bathymetry and cross-sectional shape, record water level, and measure velocity across enough of the channel and depth to understand the proposed rotor's inflow. Acoustic Doppler current profilers can characterize cross-sections, while point velocimeters can capture local velocity and turbulence near a device. Survey design must account for instrument blind zones, boat motion, uneven beds, nonuniform flow, and limited access. The field report should preserve raw observations, calibration and quality-control steps, coordinate references, and uncertainty bounds so a later analyst can reproduce the resource estimate [5].



**Figure 4. Illustrative ADCP field survey for characterizing river flow; generated illustration.**

A single campaign is rarely sufficient where river discharge changes seasonally or with upstream management. Long-term stage or flow records can place short, detailed surveys in context, but extrapolation should be validated locally. Where no long record exists, measurements should span representative operating seasons and explicitly mark unobserved periods. The power calculation should use the velocity field at the proposed device location, not simply the average speed of the entire reach. Kirby et al. report that survey conditions and channel complexity can limit the accuracy of resource assessment, and that site screening can identify reaches where detailed measurement is more likely to be useful [6].

A turbine is not hydraulically invisible. Rotor thrust and blockage can alter upstream water levels and velocity distributions, while the wake changes downstream flow. In open channels, free surfaces and channel boundaries can influence the response, particularly where the turbine occupies a substantial fraction of the cross-section. Measurement should compare baseline and operating conditions, including water levels and velocities upstream and downstream. The Department of Energy field guide emphasizes measuring both device performance and hydrodynamic effects and combining observations with numerical models [5]. This broader view prevents a design from appearing successful solely because local power is high while reach-scale effects remain unexamined.

For arrays, spacing and layout must account for wake recovery, lateral bypass flow, channel geometry, and interaction among devices. A downstream unit may receive slower or more turbulent inflow than an isolated turbine, changing energy and loading. Array output cannot be estimated reliably by multiplying a single-device result by device count unless interactions are negligible or separately modeled. Early layouts can be screened with simplified models, but detailed arrangements should be checked against measured or higher-fidelity flow data when wake interactions materially affect project value [7].

### EXPERIMENTAL VALIDATION AND MODEL CONFIDENCE

Validation should be planned before geometry optimization begins. The team should specify which quantities the model is expected to predict: torque, rotational speed, mechanical power, electrical output, thrust, pressure distribution, wake velocity, or water-level change. Instrument uncertainty and repeatability should be estimated alongside numerical discretization and model-form uncertainty. A model that matches one peak power point but misses the performance curve or thrust may not be suitable for predicting structural loads or annual production. Confidence grows when independent measurements are matched across operating points and when the same model predicts both performance and flow-field quantities.

A staged test program can limit cost while preserving traceability. Component tests can verify hydrofoil or generator behavior; rotor tests can measure torque and power across tip-speed ratios; integrated tests can add drivetrain, control system, and support; and field demonstrations can quantify realistic turbulence, water levels, debris, and access. Model-scale testing should document scale ratios, Reynolds number, blockage, free-surface effects, and instrumentation limits. Results from a model rotor should not be transferred directly to full scale without addressing relevant scale effects.




**Figure 5. Laboratory water-flume arrangement for hydrokinetic turbine testing; generated illustration.**

Riglin et al. provide an example of joined numerical and physical evaluation: a portable prototype was tested across several channel velocities, and CFD predictions were compared with measurements after accounting for generator and drivetrain losses [8]. The agreement is useful evidence for that prototype and test configuration; it does not validate every turbulence model, geometry, or river site. The broader lesson is methodological: define the measured boundary, include component losses consistently, report uncertainty, and compare the model with data collected under documented inflow and loading conditions. This is the bridge between a numerical optimum and a prototype claim.

Field demonstrations should collect enough operating data to evaluate availability, failure modes, and service effort as well as energy. Short commissioning runs can confirm function but cannot reveal the full burden of routine inspection, seasonal shutdown, component replacement, or retrieval after extreme flow. The operation log should record outages and causes, maintenance hours, damage, and periods when a waterway operator required shutdown. These records convert modeled capacity factor into evidence for lifecycle cost. Where safety or environmental monitoring is required, the plan should set thresholds and responses before installation.

## ENVIRONMENTAL AND OPERATIONAL CONSIDERATIONS

Hydrokinetic devices avoid a large impoundment, but this fact alone does not establish that a project has no environmental effects. Potential interactions depend on the device, location, species, season, and operating regime. Questions may include collision or avoidance behavior, changes in local flow and turbulence, noise, electromagnetic fields, sediment response, and effects associated with supports or cables. The technology review identifies environmental impact and stakeholder concerns as part of development rather than an afterthought [7]. The appropriate assessment is site-specific and proportionate to credible exposure pathways; this paper does not infer an effect or regulatory outcome for an unstudied location.

Operational planning can reduce risk and improve reliability. Debris interception and removal, corrosion protection, safe retrieval, inspection intervals, overspeed protection, and emergency shutdown should be designed for the local flow regime. Monitoring can determine whether operating limits should change during floods, low water, high debris loads, or sensitive ecological periods. These controls have a cost, but excluding them from the economic model would produce an incomplete estimate. A technically efficient rotor that cannot be safely serviced or operated under seasonal conditions is not deployable.

Social acceptance and waterway governance also shape feasibility. Communities may value reliable local electricity, but may also depend on the same

river for irrigation, transport, fishing, cultural practice, or recreation. Early engagement can identify seasonal restrictions and access requirements before they become redesign costs. Developers should explain what measurements will be collected, how operational effects will be monitored, and how incidents will be handled. The purpose is not to presume support or opposition; it is to ensure that design and operation reflect actual waterway uses.

## INTEGRATED RESEARCH AND DEPLOYMENT ROADMAP

The evidence reviewed here suggests a practical sequence. First, screen candidate sites for resource, bathymetry, access, and competing uses. Second, characterize velocity, water level, and seasonal variability at the candidate location. Third, select a rotor and support concept that satisfies packaging, loading, and service constraints. Fourth, use reduced-order models for broad screening, then apply CFD or optimization where expected design benefit justifies the cost. Fifth, validate baseline and optimized geometries with a common experimental protocol. Sixth, couple the measured power curve and availability with local demand, tariffs, costs, and financing. Finally, demonstrate the system long enough to document reliability and channel effects. Each stage should have a go/no-go criterion so weak resource or high balance-of-system costs are discovered before expensive fabrication.

Future studies can make the evidence more cumulative by publishing common metadata: rotor dimensions, reference area, density, velocity measurement position, turbulence intensity, Reynolds number, blockage, free-surface depth, generator and drivetrain efficiency, uncertainty, and boundary conditions. Optimization papers should provide a reproducible baseline and enough information to understand the feasible design region. Experimental papers should report mechanical and electrical boundaries where possible. Economic studies should separate resource uncertainty from price and cost uncertainty. These steps would let later reviews compare like with like and identify which improvements arise from geometry, controls, measurement quality, or site selection.

A useful research priority is a matched comparison in which a baseline rotor, a geometry-optimized rotor, and a system-level operating strategy are evaluated at one representative site. The study would measure inflow distribution and seasonal availability, test both rotors with the same instrumentation and power boundary, and operate the selected design long enough to estimate service requirements. The measured curve would then be paired with local demand and a transparent cost model. This would connect the four strands represented in the supplied studies: rotor performance, economic configuration, broad geometry exploration, and constrained refinement. Replication at a second site would indicate which results generalize and which depend on local hydraulics.

Reliability deserves a place in the optimization problem from the start. River velocity and turbulence vary over time, and extreme operating conditions can impose loads that are absent from a nominal design point. Blade, shaft, support, and anchoring requirements affect mass, cost, inspection, and retrieval. An operating envelope should state the conditions under which the turbine generates, limits power, or shuts down. Reliability modeling can identify which load cases and component uncertainties control expected service life; field logs can then update those estimates. A candidate with slightly lower peak Cp may be preferable if it avoids frequent shutdowns or can be serviced more easily.

Uncertainty should be traced from resource measurement through design and finance rather than added only as a final percentage. Measurement error affects the estimated velocity distribution; numerical error affects the predicted power curve; manufacturing tolerances affect the built rotor; and availability assumptions affect annual energy. These uncertainties interact, since a device's operating schedule can depend on both resource conditions and maintenance access. A useful project model can propagate ranges or probability distributions through annual production and cash flow, while clearly identifying which uncertainties are measured and which remain judgment-based. This makes the decision robust to evidence gaps instead of presenting a single overly precise payback number.

Finally, comparisons across sites should distinguish transferable design knowledge from local operating results. A blade-loading or duct-shape insight may inform a new design, but the annual energy and economic outcome still depend on local flow, channel geometry, waterway rules, and demand. Multi-site studies can test whether model calibration and design gains persist across locations with different depth, turbulence, and seasonal conditions. Publishing failures and neutral results is also useful: it helps distinguish a method that works only under carefully controlled conditions from one that remains effective when the deployment environment changes.

A minimum reporting framework would make these linked studies easier to interpret. Each performance report should state whether power is measured at the rotor shaft, generator terminals, or grid connection; define the reference area and velocity; and describe the position, timing, and uncertainty of flow measurements. It should give the operating curve rather than only a peak coefficient, along with thrust or structural-load data where available. Numerical reports should identify the mesh and domain checks, turbulence and rotor models, convergence criteria, and operating conditions. These details do not guarantee accuracy, but they let readers identify where results are comparable and where they are not.

Economic reports should make their boundaries equally explicit. At minimum, they should state the project lifetime, capital and replacement costs, installation and retrieval assumptions, availability, energy losses, financing or discount rate, local electricity value, and treatment of storage or backup. The energy time series or resource distribution used to estimate production should be described with its provenance and period. Reporting a base case alongside scenario ranges makes it easier to see whether feasibility is robust or depends on one uncertain input. Where the project serves local demand, the load profile should be shown or summarized at a time resolution appropriate to the storage and dispatch decisions.

A practical set of stage gates can connect engineering evidence to a deployment decision. A site-screening gate asks whether resource, access, channel geometry, and waterway use justify more field work. A concept-design gate asks whether the rotor and support can meet loading, packaging, retrieval, and service constraints. A validation gate asks whether measured performance and flow effects fall within predeclared tolerances of the model. A demonstration gate asks whether observed availability, maintenance, and safety performance support the economic assumptions. An investment gate then evaluates local cash flow and uncertainty. The criteria should be set for the project before data are collected so that the outcome does not shift after results are known.

This framework also distinguishes a successful research prototype from a viable project. A prototype can establish that a geometry is manufacturable and can produce electricity under a test condition. A project must additionally show that the device can be deployed, serviced, and operated without unacceptable effects on the waterway, and that its output has sufficient value over its life. Keeping these claims separate allows technical progress to be recognized without implying commercial readiness. The reviewed studies collectively advance important parts of the process, but field duration, site-specific validation, and transparent lifecycle data are still needed for a complete assessment.

## CONCLUSION

The reviewed studies connect turbine geometry, numerical evaluation, and project economics, but no single contribution validates the full chain from an optimized shape to long-term energy yield and verified cash flow. Modeled Cp values near 0.45 and up to about 0.50 are promising within their respective

configurations; neither value is a universal benchmark or a direct prediction of annual electrical production. The economic studies show that local demand and the value of displaced electricity can matter as much as nominal turbine output. The field and prototype literature reinforces the need to measure the site, define the power boundary, and test numerical predictions against data. A credible development pathway combines resource assessment, constrained geometry design, matched experimental validation, open-channel impact monitoring, and a transparent lifecycle model. The central research need is a sustained, site-specific demonstration that reports both energy and operational evidence. Only then can optimized geometry be judged by whether it produces reliable, serviceable, and economically useful electricity under the conditions for which it was designed.

**REFERENCES**

[1] C. M. Puertas-Frías, C. S. Willson, and P. A. García-Salaberri, "Design and economic analysis of a hydrokinetic turbine for household applications," Renewable Energy, vol. 199, pp. 587–598, 2022, doi: 10.1016/j.renene.2022.08.155.

[2] L. Bigatton, V. Dachet, D. Ernst, and R. Fonteneau, "Economic assessment of tidal hydrokinetic turbines under different energy system configurations," in Proceedings of the 39th International Conference on Efficiency, Cost, Optimization, Simulation and Environmental Impact of Energy Systems (ECOS), Constanța, Romania, Jun. 28–Jul. 3, 2026.

[3] H. M. Sheikh, T. A. Callan, K. J. Hennessy, and P. S. Marcus, "Optimization of the shape of a hydrokinetic turbine's draft tube and hub assembly using Design-by-Morphing with Bayesian optimization," Computer Methods in Applied Mechanics and Engineering, vol. 401, pt. B, Art. no. 115654, 2022, doi: 10.1016/j.cma.2022.115654.

[4] J. Park, M. Mangano, S. Seraj, B. Pacini, Y. Liao, B. G. Knight, K. Naik, K. J. Maki, J. R. R. A. Martins, J. Sun, and Y. Pan, "CFD-based design optimization of a 5 kW ducted hydrokinetic turbine with practical constraints," Renewable Energy, vol. 256, Art. no. 124304, 2026, doi: 10.1016/j.renene.2025.124304.

[5] B. Gunawan, V. S. Neary, J. Mortensen, and J. D. Roberts, Assessing and Testing Hydrokinetic Turbine Performance and Effects on Open Channel Hydrodynamics: An Irrigation Canal Case Study, U.S. Department of Energy and U.S. Bureau of Reclamation, Mar. 2017.

[6] K. Kirby, C. D. Rennie, J. Cousineau, S. Ferguson, and I. Nistor, "Practical considerations of conducting river hydrokinetic energy resource assessments," in Proceedings of the 40th IAHR World Congress, Vienna, Austria, 2023, doi: 10.3850/978-90-833476-1-5_iahr40wc-p0049-cd.

[7] N. D. Laws and B. P. Epps, "Hydrokinetic energy conversion: Technology, research, and outlook," Renewable and Sustainable Energy Reviews, vol. 57, pp. 1245–1259, 2016, doi: 10.1016/j.rser.2015.12.189.

[8] J. Riglin, F. Carter III, N. Oblas, W. C. Schleicher, C. Daskiran, and A. Oztekin, "Experimental and numerical characterization of a full-scale portable hydrokinetic turbine prototype for river applications," Renewable Energy, vol. 99, pp. 772–783, 2016, doi: 10.1016/j.renene.2016.07.065.